

# Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. **93 825 - 86 HH**

Company **Fischer**  
**Mess- und Regeltechnik GmbH**  
**Bielefelder Straße 37a**  
**32107 Bad Salzuflen, GERMANY**

Product Description **Electronic Level Switch**  
**Electrodes**

Type **NK06**

Environmental Category **C**

Technical Data /  
Range of Application

Number electrodes:	1 to 3
Working pressure:	10 bar
Media temperature max.:	60°C
Ambient temperature from:	-20°C to 50°C
Material electrode head:	brass
Material electrode:	stainless steel
Length of electrode max.:	1000 mm
Screwed plug:	G1"A
Conductivity min.:	5 µS
Appliance plug:	GDME 3011

To be used with level circuit electronic type ER76 = GT76. In case of several electrodes rods with a length of > 500 mm spacers have to be used.

Test Standard **Guidelines for the Performance of Type Approvals, Chapter 2, Edition 2003**

Documents **Data sheet : NK06,**  
**Part list no.: 07.006.02.06554.V date 04.01.1999,**  
**Drawing no.: 07.006.00.06514.2 date 04.01.1999**

Remarks **None**

Valid until **2014-04-26**

Page **1 of 1**

File No. **I.D.03**

**Hamburg, 2010-03-23**

Type Approval Symbol



**Germanischer Lloyd**

*id. Wiese*  
Matthias Wiese

*i.A. P. Schröder*  
Klaus-Peter Schröder