

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. **59 366 - 08 HH**

Company **Fischer
Mess- und Regeltechnik GmbH
Bielefelder Straße 37a
32107 Bad Salzuffen, GERMANY**

Product Description **Level Sensing Probe**

Type **NK08 210###0Z**

Environmental Category **D**

Technical Data /
Range of Application **Operating pressure: 6bar (max.)
Enclosure classification: IP65
Electrical connection: M12 connection plug, 4 pin
Max. rated voltage: 125V
Material electrode head: stainless steel 1.4305
Material electrode: stainless steel 1.4305 / Viton
Threaded stem: G 1/4 A
Length of electrode (measured from sealing surface): 60mm or 100mm**

Test Standard **Guidelines for the Performance of Type Approvals, Chapter 2, Edition 2003**

Documents **Test report : Paconsult no. 08-2053 (29.07.08), Fischer no. 2634+2646 (05.09.08)
Data sheet DB_GB_NK08.fm (05.09.08)
Drawing no. 07.080.00.02420.3 (13.08.08), part list no. 07.080.02.02420.V (12.08.08)**

Remarks **None**

Valid until **2013-09-08**

Page **1 of 1**

Type Approval Symbol



File No. **I.D.03**

Hamburg, 2008-09-09

Germanischer Lloyd

J. Wittburg
Jürgen Wittburg

K. P. Schröder
Klaus-Peter Schröder